

## Report of Analysis

3.1  
3

<b>Client Sample ID:</b> NURSES SINK-PRE-PURGE		<b>Date Sampled:</b> 10/28/21
<b>Lab Sample ID:</b> JD34334-1		<b>Date Received:</b> 10/28/21
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> New Road School of Ocean County, 810 Towbin Avenue, Lakewood, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	<0.00050	0.015	0.00050	mg/l	1	11/11/21	11/17/21 MET	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA51445

(2) Prep QC Batch: MP29564

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 9/18)

# Report of Analysis

3.2  
3

<b>Client Sample ID:</b>	NURSES SINK-POST-PURGE		
<b>Lab Sample ID:</b>	JD34334-2	<b>Date Sampled:</b>	10/28/21
<b>Matrix:</b>	DW - Drinking Water	<b>Date Received:</b>	10/28/21
<b>Project:</b>	New Road School of Ocean County, 810 Towbin Avenue, Lakewood, NJ		
		<b>Percent Solids:</b>	n/a

## Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	<0.00050	0.015	0.00050	mg/l	1	11/11/21	11/17/21 MET	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA51445

(2) Prep QC Batch: MP29564

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 9/18)

## Report of Analysis

<b>Client Sample ID:</b>	FOOD PREP-SINK PRE-PURGE	<b>Date Sampled:</b>	10/28/21
<b>Lab Sample ID:</b>	JD34334-3	<b>Date Received:</b>	10/28/21
<b>Matrix:</b>	DW - Drinking Water	<b>Percent Solids:</b>	n/a
<b>Project:</b>	New Road School of Ocean County, 810 Towbin Avenue, Lakewood, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	11/11/21	11/17/21 MET	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA51445

(2) Prep QC Batch: MP29564

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 9/18)

## Report of Analysis

3.4  
3

<b>Client Sample ID:</b>	FOOD PREP-SINK POST-PURGE	<b>Date Sampled:</b>	10/28/21
<b>Lab Sample ID:</b>	JD34334-4	<b>Date Received:</b>	10/28/21
<b>Matrix:</b>	DW - Drinking Water	<b>Percent Solids:</b>	n/a
<b>Project:</b>	New Road School of Ocean County, 810 Towbin Avenue, Lakewood, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	<0.00050	0.015	0.00050	mg/l	1	11/11/21	11/18/21 NV	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA51455

(2) Prep QC Batch: MP29564

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 9/18)



# SGS Sample Receipt Summary

Job Number: JD34334

Client: NEW ROAD SCHOOLS OF NJ, INC.

Project: NEW ROAD SCHOOL OF OCEAN COUNTY, 81

Date / Time Received: 10/28/2021 10:00:00 AM

Delivery Method: \_\_\_\_\_

Airbill #'s: \_\_\_\_\_

Cooler Temps (Raw Measured) °C: Cooler 1: (2.2);

Cooler Temps (Corrected) °C: Cooler 1: (2.2);

**Cooler Security**

Y or N

Y or N

- |                           |                                     |                          |                      |                                     |                          |
|---------------------------|-------------------------------------|--------------------------|----------------------|-------------------------------------|--------------------------|
| 1. Custody Seals Present: | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 3. COC Present:      | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Custody Seals Intact:  | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 4. Smp Dates/Time OK | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

**Cooler Temperature**

Y or N

- |                              |                                     |                          |
|------------------------------|-------------------------------------|--------------------------|
| 1. Temp criteria achieved:   | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Cooler temp verification: | <u>IR Gun</u>                       |                          |
| 3. Cooler media:             | <u>Ice (Bag)</u>                    |                          |
| 4. No. Coolers:              | <u>1</u>                            |                          |

**Quality Control Preservation**

Y or N

N/A

- |                                 |                                     |                          |                                     |
|---------------------------------|-------------------------------------|--------------------------|-------------------------------------|
| 1. Trip Blank present / cooler: | <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2. Trip Blank listed on COC:    | <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3. Samples preserved properly:  | <input checked="" type="checkbox"/> | <input type="checkbox"/> |                                     |
| 4. VOCs headspace free:         | <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

**Sample Integrity - Documentation**

Y or N

- |  |                                     |                          |
|--|-------------------------------------|--------------------------|
| 1. Sample labels present on bottles:   | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Container labeling complete:        | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3. Sample container label / COC agree: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

**Sample Integrity - Condition**

Y or N

- |                                  |                                     |                          |
|----------------------------------|-------------------------------------|--------------------------|
| 1. Sample recvd within HT:       | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. All containers accounted for: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3. Condition of sample:          | <u>Intact</u>                       |                          |

**Sample Integrity - Instructions**

Y or N

N/A


- |   |                                     |                                     |                                     |
|---|-------------------------------------|-------------------------------------|-------------------------------------|
| 1. Analysis requested is clear:           | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |                                     |
| 2. Bottles received for unspecified tests | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |                                     |
| 3. Sufficient volume recvd for analysis:  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |                                     |
| 4. Compositing instructions clear:        | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 5. Filtering instructions clear:          | <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

Test Strip Lot #s:      pH 1-12: 231619      pH 12+: 203117A      Other: (Specify) \_\_\_\_\_

Comments

SM089-03  
Rev. Date 12/7/17

4.1  
4

		<b>SGS Dayton, NJ</b> Dec 08, 2021 16:42 pm			
		<b>Job Number:</b> JD34334			
<b>Account:</b> New Road Schools of NJ, Inc.					
<b>Project:</b> New Road School of Ocean County, 810 Towbin Avenue, Lakewood, NJ					
<b>Project Number:</b>					
				Legend:	Hit
<b>Client Sample ID:</b>	<b>NURSES SINK- PRE-PURGE</b>	<b>NURSES SINK- POST-PURGE</b>	<b>FOOD PREP-SINK PRE-PURGE</b>	<b>FOOD PREP-SINK POST-PURGE</b>	
<b>Lab Sample ID:</b>	JD34334-1	JD34334-2	JD34334-3	JD34334-4	
<b>Date Sampled:</b>	10/28/2021	10/28/2021	10/28/2021	10/28/2021	
<b>Matrix:</b>	Drinking Water	Drinking Water	Drinking Water	Drinking Water	
<b>Metals Analysis</b>					
Lead	mg/l	<0.00050	<0.00050	<0.00050	